



**TÜV NORD CERT**

**Certificate about the testing of the  
degrees of protection provided by enclosures**

Testing laboratory  
Safety of technical systems

**Client:** Rolec  
Gehäuse-Systeme GmbH  
Kreuzbreite 2

D – 31737 Rinteln

**Devices under  
test:** Enclosure series aluTwin  
Serie:

AT 100, AT 160, AT 162 and ATF 100

**Tested in accordance to:** EN 60529: 2000 Degrees of protection provided by enclosures (IP Code)  
Requirements towards system of protection IP 66 and IP 67  
Enclosures of category I;  
Dust test with negative pressure

**Conductor of test:** A. Schmidt

**Order number:** 8000550727

**Period of test:** until 07.07.2003

**Result:** The enclosure series aluTwin fulfils the requirements of the degrees of protection IP 66 and IP 67

TÜV NORD CERT GmbH & Co. KG  
Am TÜV 1

D – 30519 Hannover

Hannover, 07.07.2003

  
K. H. Schwedt

Head of testing laboratory  
Safety of technical systems

