

**Labor für Umwelterprobung
und Werkstoffprüfung**

Telefon 03 41 / 4 84 32 - 25
umwelterprobung@tzoleipzig.de

TZO Leipzig GmbH - Hornstraße 5 - D-04249 Leipzig

**Technologie-Zentrum für Oberflächentechnik
und Umweltschutz Leipzig GmbH**

Telefon 03 41 / 4 84 32 - 11
info@tzoleipzig.de

Telefax 03 41 / 4 84 32 - 14
<http://www.tzoleipzig.de>

TEST CERTIFICATE

Client ROLEC Gehäuse-Systeme GmbH
Kreuzbreite 2
D – 31737 Rinteln

Date of order 2022-02-09

TEST OBJECT

Enclosure of series aluDOOR, with recessed lid

Size ADF112 Size ADF152 Size ADF172

**The certificate is valid in connection with the test report
No. 045/22**

The specimens were tested in accordance with DIN EN 60529 : 2014-09 (VDE 0470–1)
to determine the degrees of protection IP Code 66 and IP Code 67.

The specimen was tested in accordance with ISO 20653 : 2013-02
to determine the degree of protection IP Code X9K.

Criteria for passing the tests

- IP 6X No dust shall enter into the enclosure.
- IP X6 No water shall enter into the enclosure.
- IP X7 No water shall enter into the enclosure.
- IP X9K No water shall enter into the enclosure.

TEST DECISION

The specimens have passed the above mentioned tests.

Leipzig, 2022-02-14

**Laboratory for Environmental
Testing and Material Testing**



Dr.-Ing. Frank Erler
Laboratory Manager